FD30/0

Glass:	Gasket:	Liner:*	Bead:
6mm GFS6-60/0	tg3 20 x 2mm	79 x 32mm	34 x 27mm
7mm GFP7-30/0	cc 12 x 5mm	79 x 32mm	33 x 27mm


Splayed Bead Se



VisionLine Firescreen FD30/30


Glass:	Gasket:	Liner:*	Bead:
16mm GFP16-60/30	cc 12 x 5mm	79 x 32mm	27 x 27mm






FD30/0

Glass:	Gasket:	Liner:*	Bead:
12mm GFP12-60/0	cc 12 x 5mm	79 x 32mm	31 x 27mm
13mm GFP13-30/0	cc 12 x 5mm	79 x 32mm	31 x 27mm
12mm GFS12-60/30	tg3 20 x 2mm	79 x 32mm	31 x 27mm




VisionLine Firescreen FD60/60

Glass:	Gasket:	Liner:*	Bead:
25mm GFP25-60/60	cc 12 x 5mm	104 x 32mm	37 x 27mm



FD30/30

Glass:	Gasket:	Liner:*	Bead:
16mm GFP16-60/30	cc 12 x 5mm	79 x 32mm	27 x 27mm




Notes:

* Perimeter and verticle glazed liner FD30 Firescreen door mullion and transom liner 79x44mm FD60 Firescreen door mullion and transom liner 104x44mm

Splayed Bead has a 15° angle from the top of the bead

FD60/0

Glass:	Gasket:	Liner:*	Bead:
12mm GFP12-60/0	cc 12 x 5mm	104 x 32mm	44 x 27mm
6mm GFS6-60/0	tg6 25 x 4mm	104 x 32mm	45 x 27mm
12mm GFS12-60/30	tg6 25 x 4mm	104 x 32mm	42 x 27mm
6mm GFS6-60/0	tg6 25 x 4mm	104 x 32mm	45 x 27mr




Gasket:

cc - Closed-cell Foam tg3 - Therm-A-Glaze 30 tg6 - Therm-A-Glaze 60

FD60/30

Glass:	Gasket:	Liner:*	Bead:
16mm GFP16-60/30	cc 12 x 5mm	104 x 32mm	41 x 27mm



Title Glazing Details - Minimum Dimensions for Timber Frame Firescreens

Sheet 1 of 1 Date 22/07/2014

Issue 4 Dwg No FZD0415

FD60/60

Glass:	Gasket:	Liner:*	Bead:
25mm GFP25-60/60	cc 15 x 5mm	104 x 32mm	37 x 27mm

